

Overtime Report September 1-30, 2024

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
Sean Bernard	9/11/2024	18:45	2	Coagulant loss of flow	Responded to the plant, coagulant in alarm for loss of flow, purge tank level low. Shut the plant down due to low pond levels.