

## Overtime Report July 2024

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
John Gibson	7/7/2024	18:09	1	FF Common High Alarm	Logged in remotely, FFB in an extended purge cycle due to high turbidity. Reset multiple times until the turbidity dropped back within limits and the filter resumed operation.
John Gibson	7/15/2024	21:01	2	FF Common High Alarm	Logged in remotely, FFA in a purge cycle, FFB dirty waiting to wash, purge tank volume dropping and FFA turbidity still >2ntu. Shut down FFA to prevent a plant shutdown from a low purge tank level. FFB began its wash cycle. Responded to the plant and restarted FFA.